



## TESTING AND MEASURING EQUIPMENT/ALLOWED SUBCONTRACTING

### Non sheathed cables for fixed wiring

#### IEC 60227-3 2. Edition (1993-02) + Edition 2.1 (1997-11) + Am. 1 (1997-07)

R=Required by Lab  
S=May be subcontracted

Ref. No.	Measurement/testing	Testing / measuring equipment / material needed	Subcontracting
In general		Testing equipment according to IEC 60227-2 and additional tests.	
IEC 60811-3-2 Sub Clause 9	Thermal stability for insulation.	Glass tubes made of AR-glass closed at one end, length: 110 mm, outer diameter approx. 5 mm, inner diameter $4,0 \pm 0,5$ mm. Universal indicating paper with a pH range of 1 to 10. Thermostatically controlled heatable oilbath for $200 \pm 0,5$ °C. Calibrated thermometer with divisions of 0,1 °C, stop-watch.	R