

## COLLECTION OF CTL DECISIONS

<b>Standard:</b> IEC 60570/2003	<b>Sub clause:</b> General	<b>Sheet N°:</b> 203/03 <b>Page:</b> 1 (1)
<b>Subject:</b> Connector with a flexible cord and a normal plug	<b>Key words:</b> - Connector - Flexible cord - Contacts	<b>Meeting:</b> OSM/LUM No. 14 WG1 No. 1 - 2 Item: 6.17.3
<p><b>Question:</b> Electrical supply track system with a flexible cord and a normal plug. The contacts are touchable in the unmounted position. Can this construction be accepted?</p> <p><b>Decision:</b> Such a construction is not acceptable.</p> <p><b>Explanatory notes:</b> --</p>		

