

COLLECTION OF CTL DECISIONS

Standard: IEC 60570/2003	Sub clause: 1	Sheet N°: 204/03 Page: 1 (1)
Subject: Luminaires with socket outlet connected to track system	Key words: - Socket-outlet - Track system - Luminaires	Meeting: OSM/LUM No. 5 WG1 No. 1 - 2 Item: Page 14
<p>Question: Can a luminaire with a built in socket-outlet be accepted for connection to the electrical track system for luminaires?</p> <p>Decision: Luminaires with general purpose socket-outlet are not acceptable.</p> <p>Explanatory notes: --</p>		

