

## COLLECTION OF CTL DECISIONS

<b>Standard:</b> IEC 60570/2003	<b>Sub clause:</b> 2.3.3.9 5.13	<b>Sheet N°:</b> 205/03 <b>Page:</b> 1 (1)
<b>Subject:</b> IP 40 indication	<b>Key words:</b> - Common conclusion - IP 40 indication - L.I.P.	<b>Meeting:</b> OSM/LUM No. 14 WG1 No. 1 - 2 Item: 6.17.1
<p><b>Question:</b> IP 40 indication on electrical supply track system for luminaires.</p> <p><b>Decision:</b> The "IP 40" indication is not acceptable.</p> <p><b>Explanatory notes:</b> --</p>		

