

COLLECTION OF CTL DECISIONS

Standard: IEC 60598-1/1999	Sub clause: General	Sheet N°: 003/03 Page: 1 (1)
Subject: IEC 62262	Key words: <ul style="list-style-type: none">- IEC 62262- IK code- Degrees of protection	Meeting: OSM/LUM No. 16 WG1 No. 1 - 2 Item: 8.1.29
<p>Question: IEC 62262 - Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code). We would like to ask which requirements should be applied for luminaires.</p> <p>Decision: The standard for luminaires (§ 4.13) applies; IK code is voluntary and no substitutes IEC 60598-1 requirements.</p> <p>Explanatory notes: --</p>		

