

## COLLECTION OF CTL DECISIONS

<b>Standard:</b> IEC 60598-1/1999	<b>Sub clause:</b> 0.4	<b>Sheet N°:</b> 012/03 <b>Page:</b> 1(1)
<b>Subject:</b> Floodlight with mounting accessories	<b>Key words:</b> - Floodlight - Mounting accessories - Part of installation	<b>Meeting:</b> OSM/LUM No. 17 WG1 No. 1 - 2 <b>Item:</b> 8.1.3
<p><b>Question:</b> The figures given in Annex describe different mounting possibilities for a floodlight.</p> <ol style="list-style-type: none"> <li>1) Figure A: floodlight alone.</li> <li>2) Figure B: floodlight with accessory wall bracket + connecting box.</li> <li>3) Figure C: floodlight with accessory wall bracket + connecting box including terminal.</li> <li>4) Figure D: floodlight with accessory wall bracket + connecting box including terminal and cord for internal wiring.</li> </ol> <p>When the accessories are delivered with the luminaires, which configurations are acceptable?</p> <p><b>Decision:</b> Figures A-B-D - acceptable. Note for B: installation instructions are required. Figure C - not acceptable, because internal wiring is missing between the lamp compartment and the terminal block in the wall bracket.</p> <p><b>Explanatory notes:</b> --</p>		

