

COLLECTION OF CTL DECISIONS

Standard: IEC 60598-1/1999	Sub clause: 1.2.24	Sheet N°: 023/03 Page: 1(1)
Subject: Class III luminaire	Key words: <ul style="list-style-type: none">- Non-detachable- Transformer- SELV	Meeting: OSM/LUM No. 16 WG1 No. 1 - 2 Item: 8.1.3
<p>Question: Can a luminaire supplied with a generic independent transformer or convertor providing a declared voltage in the limit of SELV be considered a class III luminaire?</p> <p>Decision: If the luminaire is non-detachable to the transformer, it is a class II luminaires.</p> <p>Explanatory notes: --</p>		

