

COLLECTION OF CTL DECISIONS

Standard: IEC 60598-1/1999	Sub clause: 3	Sheet N°: 024/03 Page: 1(1)
Subject: Definition of basic type reference	Key words: - Rated wattage - Type reference - Separately marked	Meeting: OSM/LUM No. 9 WG1 No. 1 - 2 Item: 3.4
<p>Question: Definition of basic type reference. There was considerable discussion, particularly regarding ranges of luminaires. Most participants agreed that one type reference could cover different voltages and wattages (provided these were separately marked) and different colours.</p> <p>Decision: The rated wattage must be marked separately from the type reference was confirmed although it could also be part of the reference. In addition the rated wattage must be marked separately from the type reference, it has to be noted that the manufacturer must have some freedom with regard the type reference of a luminaire. Amendment 1 to IEC 60598 has reconstructed the marking clause, but also here common sense is applicable. In addition confused marking shall not be used (e.g. IP 68, 30 Lm or 200 V, used as type reference).</p> <p>Explanatory notes: --</p>		

