

COLLECTION OF CTL DECISIONS

Standard: IEC 60598-1/1999	Sub clause: 3.2.2	Sheet N°: 026/03 Page: 1(1)
Subject: Rated voltage marking	Key words: <ul style="list-style-type: none">- Filament lamps- Rated voltage- Marking	Meeting: OSM/LUM No. 16 WG1 No. 1 - 2 Item: 8.1.4
<p>Question: Luminaires for tungsten filament lamps shall be marked only if the rated voltage is different from 250V; is it acceptable “250V” on the luminaire marking?</p> <p>Decision: It's acceptable.</p> <p>Explanatory notes: --</p>		

