

## CTL DECISION SHEET

<b>Standard:</b> IEC 60570/2003	<b>Sub clause:</b> General	<b>Sheet N°:</b> 557/06 <b>Page:</b> 1 (1)
<b>Subject:</b> Openings for the adapters	<b>Key words:</b> - Construction - Openings - Adapters	<b>Meeting:</b> Decision confirmed at 44 <sup>th</sup> CTL meeting
<p><b>Question:</b> Is it acceptable to have an electrical supply track system with the openings for the adapters facing upwards?</p> <p><b>Decision:</b> Such a construction that is not on or in the floor can still comply with the standard.</p> <p><b>Explanatory notes:</b> --</p>		