

## CTL DECISION SHEET

<b>Standard(s):</b> IEC 61558-1/1997 A1/1998	<b>Sub clause(s):</b> 14.2	<b>Sheet N°:</b> 590/06 <b>Page:</b> 1(1)
<b>Subject(s):</b> Temperature of supports for transformers IP 00	<b>Key words:</b> - Temperature of supports - IP 00 - TRF	<b>Meeting:</b> Decision confirmed at 44 <sup>th</sup> CTL meeting
<p><b>Question:</b> Note 1 of clause 14.2 states: “ In the case of transformers with a protection index IP00, the temperature of the support is measured, but the values given in tables 1 and 3 are not considered”.</p> <p>Does this mean that the temperature of the support must always be given in the TRF as an informative value?</p> <p><b>Decision:</b> Yes.</p> <p><b>Explanatory notes:</b> --</p>		