

**COLLECTION OF THE CTL DECISIONS
DECISION SHEET**

Standard(s): IEC 60950 (1999) 3rd Ed.	Sub clause(s): Scope	Sheet No.: 396
Subject: Testing of Pluggable Type A multi-way power blocks containing MOVs and / or GDTs	Key words: - Scope	Decision taken at the 39th meeting 2002
Question: Do you consider that Pluggable Type A multi-way (x4 or x6) power blocks containing Surge Suppression components are covered by the scope of IEC 60950? Decision: If the Power Block is an integral part of a product, subject to assessment under IEC 60950, then it could also be assessed to the same standard. If the power distribution unit or power strip is a general use device intended for use with a variety of products, then the appropriate general use IEC standard shall be used.		