



**IECEE OD-2012**

Edition 2.4 2019-06-05

# **IECEE OPERATIONAL DOCUMENT**

**IEC System of Conformity Assessment Schemes for Electrotechnical Equipment  
and Components (IECEE System)**

---

**Subcontracting of Testing Activities**





**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2019 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### **About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### **About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### **Useful links:**

IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

## CONTENTS

CONTENTS .....	2
FOREWORD .....	3
1 General principles.....	4
2 Concept of subcontracting.....	4
3 Requirements .....	4
4 Records .....	6

## FOREWORD

### Scope

The concept and requirements for subcontracting.

### Document Owner

PAC

### History of changes

Revision Date	Brief summary of changes
2018-10-11	Correction of clause 2.2 from Specialized Testing Facility corrected to Specialized Testing Laboratory
2018-02-15	Deletion of subclause 1.3 c) Renaming of clause 2 In Subclause 2.2, deletion of c) and addition of two notes. Clarification in items 3.1 and 3.5 Addition of a note subclause in 3.6 Removal of some text in subclause 3.7 Addition of a new clause 4 on records.
2016-06-01	Subclause 1.1, 2.2, 3.6 to 3.8 were modified due to replacement of ACTL by SPTL

Effective date	Next maintenance due date
2019-06-05	2022-06-05

## 1 General principles

**1.1** In the IECEE System, a full CBTL shall have the capability to carry out the full test program necessary for an NCB to issue a CBTC, i.e. must have all “Required” test equipment. However, it is recognized that for particular types of tests, subcontracting may be necessary.

**1.2** The subcontractor facility must comply with the applicable requirements of ISO/IEC 17025, and relevant IECEE requirements.

**1.3** The following criteria are used for determining when subcontracting is permitted:

- a) Large and expensive equipment/facility that is rarely used, e.g. vibration test (IEC 60065), high-capacity short circuit test, over 10KA (IEC 60947). Such tests can be performed either by a subcontractor or by CBTL staff at the facility of the subcontractor.
- b) Special test equipment/facility that only the product manufacturers may possess, e.g. test facilities for radiation-emitting equipment (IEC 60601)
- c) Subcontracting for capacity reasons (Clause 3.7 a)

## 2 Concept of subcontracting

**2.1** Subcontracting is defined as performing tests and measurements at a facility other than the one operated by the CBTL.

### 2.2 Categories of subcontracting

The activities of subcontracting cover the following testing options:

- a) Subcontracting to another CBTL
- b) Subcontracting to an outside lab
- c) Borrowing or renting of test equipment for a period of less than 1 year.

Notes:

1. CTF testing covered in IECEE OD-2048 is not considered to be subcontracting.
2. Testing at a SPTL covered in IECEE 02-2, Clause 6, is not considered to be subcontracting.

In the CTL Test Equipment Lists, as per IECEE OD-5003:

- “S” – Test that may be subcontracted
- “W” – Test that may be witnessed at a CTF, another CBTL, or an outside subcontractor
- “SP”- Test that may be performed at a Specialized Testing Laboratory (SPTL)

Note: “R” on a CTL Test Equipment List stands for Required test equipment, which means that the specific test is not intended to be subcontracted and that a CBTL is generally required to have such test equipment and testing competency.

## 3 Requirements

**3.1** The following types of subcontracting may be used:

- a) A testing facility already registered in the IECEE System for that particular test.
- b) A qualified testing facility not registered in the IECEE System for that particular test.

**3.2** The subcontracting CBTL and the subcontractor shall sign a Subcontracting Agreement, except as provided below:

- CBTLs within the same corporate family, when operating under the same quality system, which includes a properly implemented procedure for subcontracting pertaining to IECEE operations.

- Subcontractable (“S”) tests not yet required by the CBTL (e.g. the test is an alternate test or is not required for the types of products tested by the CBTL).

**3.3** The subcontracting CBTL shall have documented quality system procedures for sample shipment to the subcontractors, regardless of the distance and location which include provisions to prevent any damage or other impact to the sample that may affect the testing/measurement results. .

**3.4** The subcontracted test(s) shall be compatible with the type test sequence determined by the standard(s), i.e. a full sequence of tests may be subcontracted to ensure that there is no disruption of the test sequence.

**3.5** CBTL shall exercise full control over its subcontractors in accordance with the relevant requirements of ISO/IEC 17025, the NCB/CBTL’s quality system, and the IECEE procedures.

All subcontractors shall be qualified through an initial assessment and shall be re-assessed annually or as needed if used rarely.

- NCB/CBTL shall carry out subcontractor assessments utilizing qualified assessors and document the assessment using an appropriate assessment report form.
- IECEE Peer Assessment Team may request to extend the CBTL assessment to include a subcontractor location, to validate the test equipment and subcontractor’s competency, after consultation with the IECEE Secretary.
- For tests that are allowed to be subcontracted, existing accreditation of the subcontractor by ILAC MRA signatory may be recognized together with an administrative assessment of the subcontractors technical competence.
- There is no need for additional assessment for IECEE registered testing facilities used as subcontractors since they are already under the Peer Assessment Program. Compliance with the IECEE rules should be checked through a documentation review at the subcontracting CBTL.
- A subcontractor used by more than one NCB/CBTL not in the same corporate family shall be independently qualified by each responsible NCB/CBTL and shall be subject to validation.

Note: For multiple NCBs within a corporate family, one NCB can be appointed as the responsible NCB for this purpose

**3.6** Only one level of subcontracting is permitted. Therefore, no subcontracting is permitted by subcontractor laboratories.

Note: No subcontracting is permitted by CTF or SPTL laboratories.

**3.7** Exceptions to the rule on “Required” equipment

- a) In special cases, when the CBTL possesses the “Required” test equipment but the CBTL workload exceeds the testing capacity for this particular test, the CBTL is permitted to subcontract any part of the test program on a temporary basis to a registered CBTL.
- b) For "Required Special Large Size testing and Measuring Equipment" that is seldom needed, the test that is specified in the CTL Lists as “Required” (“R”) is permitted to be subcontracted.

In such cases, the following requirements apply:

- CBTL shall provide to the IECEE Secretariat the CBTL’s agreement/contract for the subcontracted testing, and on a yearly basis - a declaration stating how many times it was necessary for the CBTL to subcontract the testing.
- If the CBTL needs to subcontract the test 10 times in total, or more than 3 in any one year, the CBTL is required to have the equipment in its possession. In such cases, the CBTL shall provide the IECEE Secretariat the evidence that the equipment has been installed, calibrated and put into operation, and that the CBTL's staff have been trained in the use of the equipment.

### **3.8 Borrowing or renting of test equipment**

- a) The CBTL and the owner of the borrowed or rented test equipment shall have an Agreement/Contract to establish the responsibilities for the calibration, use and maintenance of the equipment, in accordance with OD-5011.
- b) The CBTL shall have appropriate provisions to ensure that the transportation of the borrowed/rented test equipment will not affect the correct functioning of the equipment.
- c) The IECEE Peer Assessment Team shall verify the competence of the CBTL staff to properly use such equipment, as well as the compliance of this testing/measurement equipment with the CTL and the applicable standard's requirements.
- d) In cases, when it is impractical to ship the borrowed or rented equipment to the CBTL facilities, e.g. extra size of humidity chamber, it is permitted that the CBTL staff carries out the relevant testing/measurement at the facility of the owner of the borrowed or rented equipment.

## **4 Records**

In all cases the responsible NCB/CBTL shall maintain a register of all subcontractors that it uses and the evidence of subcontractors compliance.

**INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION**

3, rue de Varembé  
PO Box 131  
CH-1211 Geneva 20  
Switzerland

Tel: + 41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

**IEC SYSTEM OF CONFORMITY ASSESSMENT  
SCHEMES FOR ELECTROTECHNICAL  
EQUIPMENT AND COMPONENTS (IECEE)**

IECEE Secretariat c/o IEC  
3, rue de Varembé  
PO Box 131  
CH-1211 Geneva 20  
Switzerland

Tel: + 41 22 919 02 11  
[secretariat@iecee.org](mailto:secretariat@iecee.org)  
[www.iecee.org](http://www.iecee.org)