



TESTING AND MEASURING EQUIPMENT/ALLOWED SUBCONTRACTING
IEC 60934:2000-10+A1:2007-01, Edition 3.0
Circuit breakers for equipment (CBE)

R = Required to be at Lab
S = May be subcontracted
W = May be witnessed at MTL
SF = Specialized Facility
3PPS = Three Phase Power Supply required

Clause	Measurement/testing	Testing / measuring equipment / material needed	Subcontracting
9.3	Indelibility of marking	Piece of cotton, Water, Petroleum spirit (definition see note in sub-clause)	R
9.4	Reliability of screws, current carrying parts and connections	Torque screwdrivers or spanners Settings: 0.2 to 10.0 Nm OBS: Calibration of each torque-setting before use	R
9.5	Reliability of terminals for external conductors	Dynamometer for pulling force or 6 weights of: 40 – 50 – 60 – 80 – 90 and 100 N Rigid and flexible standard copper conductors	R
9.6	Protection against electric chock	Standard test finger, Figure 7, with electric contact indicator showing contact with live parts Recommendation: A lamp to be used for indication of contact and the voltage shall be not less than 40 V	R

Clause	Measurement/testing	Testing / measuring equipment / material needed	Subcontracting
9.7	Electric properties	Humidity cabinet: - Relative humidity maintained between 91 % and 95 %RH - Air temperature between 20 and 30 °C within ± 1 °C Insulation resistance meter: - Voltage output approximately 500 V d.c. Dielectric strength test equipment: - Test voltage, 250 to 2000 Vrms - Frequency, between 45 Hz and 65 Hz - Minimum short-circuit current: 0.2 A - No over current tripping when current is lower than 100 mA	R
9.8	Temperature rise	Power supply and load equipment: - Current output up to 125 A - Voltage, up to 440 alt. 630 V a.c. up to 250 V d.c. Temperature measuring equipment with fine wire thermocouples or equivalent means	R
9.9	28-days test	Auxiliary switch making cycles of 21 h / 3 h with / without current flowing Temperature measuring equipment with fine wire thermocouples or equivalent means	R
9.10	Tripping characteristics	Current load equipment: up to 750 A Tripping-time measuring equipment: 0.001 sec. to 1000 sec. Heating cabinet: $+40 \pm 2$ °C Cold Cabinet: -5 ± 2 °C	R 3PPS

Clause	Measurement/testing	Testing / measuring equipment / material needed	Subcontracting
9.11	Electrical capability	<p>Making and breaking operation. Load equipment system consisting of resistors and reactors connected in series For air-core reactors, resistors taking approx. 0.6 % of the current through the reactors must be available For iron-core reactors, the iron power losses shall not appreciably influence the recovery voltage. Power supply, 3 phase system: - current: up to 750 A, quantities: 5 % - voltage: 440 V a.c., 250 V d.c., quantities: 5 % - frequencies: 50/60 Hz, quantities: 5 % - $\cos \varphi = 0,2 - 0,98$ Device for operating the test-sample: - setting of time of close/open position, 1 sec. to 80 sec.</p>	R
9.12	Short-circuit test	<p>The voltage for the short circuit test must be so designed that the value of the applied voltage is that which is necessary to produce the specified power frequency recovery voltage. The value of the power frequency recovery voltage in each phase shall be equal to a value corresponding to 105 % of the rated operational voltage of the test-sample. The auxiliary switch A in Figure 3 to 6 shall be synchronized with respect to the voltage wave. Tolerances on the test quantities: - current: + 5 % - voltage: ± 5 % (including power-frequency recovery voltage) - frequency: ± 5 %</p>	<p>R: For rated shortcircuit current up to 3.000 A</p> <p>S For rated shortcircuit current above 3.000 A</p> <p>3PPS</p>
9.13	Resistance to mechanical shock and impact	Test-specifications under consideration	-

Clause	Measurement/testing	Testing / measuring equipment / material needed	Subcontracting
9.14	Resistance to heat	Heating cabinet: - 75 ± 2 °C - 100 ± 2 °C - 125 ± 2 °C Standard test finger: - push-force: 5 N Ball-pressure test equipment: - diameter of steel ball: 5 mm - pressure force: 20 N - support steel plate	R
9.15	Resistance to abnormal heat and to fire	Glow-wire test procedure and equipment in accordance to IEC 60695-2-1/0	R
9.16	Resistance to tracking	Tracking test procedure and equipment for determine CTI in accordance to IEC 60112	R
9.17	Resistance to rusting	Procedure for degreasing and treatment of parts to be tested: - cold chemical degreaser, methyl-chloroform or refined petrol - 10 % solution of ammonium chloride in water, 20 ± 5 °C - box (desiccator) containing air satiated with moisture, 20 ± 5 °C - heating cabinet, 100 ± 5 °C	R
Annex L	Test of suitability for isolation	Impulse voltage generator 1,2/50 μ s, 8 kV min. Leakage current meter (< 2 mA)	R