

TESTING AND MEASURING EQUIPMENT/ALLOWED SUBCONTRACTING
IEC 60670-22:2003/AMD1:2015, Edition 1.0
Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 22: Particular requirements for connecting boxes and enclosures

“R”	Required
“S”	May be subcontracted, see OD 2012
“SPTL”	Specialized Facility, see IECEE 02-2
“W”	Witness testing in the categories “MED” and “MEAS”
“3PPS”	Three Phase Power Supply required

Clause	Measurement/testing	Testing / measuring equipment / material needed	Subcontracting
In general	-	Testing equipment according to IEC 60670-1 is suitable for the purpose of this part, as applicable, with the addition given below	R
16.101.1	Protection against access to live parts	Test probe B of IEC 61032	R
16.102	Temperature rise	AC source up to 125 A Temperature measuring instruments Current measuring devices	R
17	Creepage distances, clearances and distances through sealing compound	Appropriate measuring device for distances	R