

TESTING AND MEASURING EQUIPMENT/ALLOWED SUBCONTRACTING
IEC 60670-23:2006/AMD1:2016, Edition 1.0

Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 23: Particular requirements for floor boxes and enclosures

“R”	Required
“S”	May be subcontracted, see OD 2012
“SPTL”	Specialized Facility, see IECEE 02-2
“W”	Witness testing in the categories “MED” and “MEAS”
“3PPS”	Three Phase Power Supply required

Clause	Measurement/testing	Testing / measuring equipment / material needed	Subcontracting
In general	-	Testing equipment according to IEC 60670-1 is suitable for the purpose of this part, as applicable, with the addition given below	R
15.101	Compression test	Dynamometer (range up to 1000 N) or suitable apparatus Cylinder for application of 500 N on an area of 1 cm ² (Figure 101) Stop watch Deflection measurement apparatus Sheet of plywood 9 mm thick	R